

Suggested Specification

SECTION 10 26 23

Wallguard.com PVC Free (PETG) Wallcovering 2400P.2

PART 1 GENERAL

1.01 SUMMARY

- A. This section includes the following wall protection system:
 - 1. Rigid Sheet Protective Wall Covering
- B. Related Sections
 - 1. Section 10 26 13 - Corner Guards
 - 2. Section 10 26 16 – Bumper Guards
 - 3. Section 10 26 33 - Door and Frame Protection
 - 4. Section 09 22 00 - Supports for Plaster and Gypsum Board

1.02 REFERENCES

- A. Abbreviations and Acronyms
 - 1. National Fire Protection Association (NFPA)
 - 2. American Society for Testing and Materials (ASTM)
 - 3. Underwriters Laboratories (UL)
 - 4. American National Standards Institute (ANSI)

1.03 SUBMITTALS

- A. General: Submit the following in accordance with Section 01 33 00 “Submittal Procedures”.
- B. Product Data
 - 1. Data sheet illustrating product dimensions, options, and related components.
 - 2. Installation instructions.
- C. Samples for verification of design suitability, color, and finish.
 - 1. Cut sample 12” (304) x 12” (304) in thickness specified.
- D. Test reports from a qualified independent laboratory showing results in compliance to requirements indicated

1.04 QUALITY ASSURANCE

- A. Manufacturer to have no less than 5 years experience in the production of wall protection products having successful in-service performance.
- B. Color Control: Provide extruded and molded components that meet visual and colorimetric evaluation of color to a controlled standard.
 - 1. Colorimetric evaluation less than or equal to 1.0 CMC DE (Delta E) when measured under cool white fluorescent lighting.

1.05 DELIVERY, STORAGE, AND HANDLING

- A. Storage: Store wall protection products in original packaging. Protect from weather, extreme temperatures, and moisture.
 - 1. Maintain temperature during storage between 40°- 100°F (4°- 38°C).
 - 2. Store materials flat to prevent twisting or sagging of cartons.
- B. Handling: Take adequate measure to prevent damage to materials. Avoid exposure of plastic products to direct sunlight.

1.06 SITE CONDITIONS

- A. Ambient Conditions: Do not install wall protection products until installation areas are enclosed and weatherproof. HVAC system must be operational and maintaining temperature at 65°-75°F (18°-24°C) for at least 72 hours prior to installation.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Wallguard.com
PO Box 1109
Dover Plains, NY 12522
877-943-6826
www.wallguard.com

2.02 DESCRIPTION

- A. Model 2400P.2, rigid wall covering, .030" (.76) thickness with Windrift texture. Available in standard flat sheet widths of 36" (.91m) and 48" (1.22m), and lengths of 96" (2.44m) and 120" (3.05m). Custom width and length dimensions are available. Specify color-matched caulk or extruded profile trim for edges and seams. Select from manufacturer's standard or custom colors.

2.03 DESIGN AND PERFORMANCE CRITERIA

- A. Flammability Characteristics: Extruded PETG components.
 - 1. Class A Interior wall finish (NFPA 101 Life Safety) when tested in accordance with ASTM E84.
 - a. Flame Spread: 25 or less
 - b. Smoke Developed: 450 or less
- B. Stain Resistance: Extruded PETG components.
 - 1. Material to be tested for stain resistance to various chemical reagents in accordance with ASTM D1308.
- C. Impact Resistance: Extruded PETG components.
 - 1. Unnotched Impact Strength ASTM D4812, 50 ft-lbs/in average, no break.

2.04 MATERIALS

- A. Rigid Sheet: Extruded PETG, nominal 0.030" (.76) thickness, colored throughout.
- B. Trim Profiles: Extruded thermoplastic, nominal .025" (.64) thickness.
- C. Color-Matched Caulk: Evaporative cure, elastomeric acrylic (latex) sealant with adhesive and silicone additives. Contains SKANE™ M-8 formaldehyde-free mildewcide.

2.05 ACCESSORIES

- A. Adhesive:
 - 1. Model ADH-60 low VOC mastic adhesive.
- B. Trim Profiles:
 - 1. Top/End cap trim.
 - 2. Joint/Seam cover.
 - 3. Inside corner trim.
 - 4. Outside corner trim.
- C. Color-Matched Caulk: 10.5 fl-oz cartridge.

D. Installation Tools:

1. Trowel, combination 1/16" (1.6) square-notch and 1/8" (3) V-Notch trowel.
2. Heavy pressure roller.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Examine walls for availability of backing to ensure secure attachment of wall protection products.
- B. Verify that HVAC is operating and installation area temperature has been maintained between 65°-75°F (18°-24°C) for at least 72 hours prior to installation.
- C. Verify application of wall finishes has been completed in accordance with project finish plan.

3.02 PREPARATION

- A. Surface Preparation: Clean substrate to remove dust and debris.

3.03 INSTALLATION

- A. Acclimate materials to building conditions for at least 24 hours prior to installation.
- B. Install wall protection products in accordance with manufacturer's installation instructions.

3.04 PROTECTION

- A. Protect installed material from damage by other trades. Use materials that will not mark, stain, or leave residue on the product.