#### Suggested Specification SECTION 10 26 13 Wallguard.com Defender NOW Series PVC Free 2300P

# PART 1 GENERAL

### 1.01 SUMMARY

- A. This section includes the following wall protection system:
  - 1. Corner Guards
- B. Related Sections
  - 1. Section 10 26 16 Bumper Guards
  - 2. Section 10 26 23 Protective Wall Covering
  - 3. Section 10 26 33 Door and Frame Protection
  - 4. Section 09 22 00 Supports for Plaster and Gypsum Board

### **1.02 REFERENCES**

- A. Abbreviations and Acronyms
  - 1. National Fire Protection Association (NFPA)
  - 2. American Society for Testing and Materials (ASTM)
  - 3. Underwriters Laboratories (UL)
  - 4. American National Standards Institute (ANSI)

### **1.03 SUBMITTALS**

- A. General: Submit the following in accordance with Section 01 33 00 "Submittal Procedures".
- B. Product Data
  - 1. Data sheet illustrating product dimensions, options, and related components.
  - 2. Installation instructions.
- C. Samples for verification of design suitability, color, finish, accessory cap attachment and alignment.
  - 1. 12" (304) Long sample with attached closure cap.
- D. Test reports from a qualified independent laboratory showing results in compliance to requirements indicated

### **1.04 QUALITY ASSURANCE**

- A. Manufacturer to have no less than 5 years experience in the production of wall protection products having successful in-service performance.
- B. Color Control: Provide extruded and molded components that meet visual and colorimetric evaluation of color to a controlled standard.
  - 1. Colorimetric evaluation less than or equal to 1.0 CMC DE (Delta E) when measured under cool white fluorescent lighting.

## 1.05 DELIVERY, STORAGE, AND HANDLING

- A. Storage: Store wall protection products in original packaging. Protect from weather, extreme temperatures, and moisture.
  - 1. Maintain temperature during storage between  $40^{\circ}$   $100^{\circ}F(4^{\circ}$   $38^{\circ}C)$ .
  - 2. Store materials flat to prevent twisting or sagging of cartons.
- B. Handling: Take adequate measure to prevent damage to materials. Avoid exposure of plastic products to direct sunlight.

#### **1.06 SITE CONDITIONS**

A. Ambient Conditions: Do not install wall protection products until installation areas are enclosed and weatherproof. HVAC system must be operational and maintaining temperature at 65°-75°F (18°-24°C) for at least 72 hours prior to installation.

# PART 2 PRODUCTS

## 2.01 MANUFACTURERS

A. Wallguard.com PO Box 1109 Dover Plains, NY 12522 Tel: 877-943-6826 www.wallguard.com

# 2.02 DESCRIPTION

A. Model 2300P, 3" (76) x 3" (76) x 90° Surface mounted corner guard system with a continuous aluminum retainer, 1/4" (6) radius snap-on plastic cover, and molded top and bottom closure caps. Select color from manufacturer's standard or custom colors.

## 2.03 DESIGN AND PERFORMANCE CRITERIA

- A. Flammability Characteristics: Extruded PETG components.
  - 1. Class A Interior wall finish (NFPA 101 Life Safety) when tested in accordance with ASTM E84.
    - a. Flame Spread: 25 or less
    - b. Smoke Developed: 450 or less
- B. Stain Resistance: Extruded PETG components.
  - 1. Material to be tested for stain resistance to various chemical reagents in accordance with ASTM D1308.
- C. Impact Resistance: Extruded PETG components.
  - 1. Unnotched Impact Strength ASTM D4812, 50 ft-lbs/in average, no break.

## 2.04 MATERIALS

- A. Cover: Extruded PETG, nominal 0.080" (2) thickness, colored throughout.
- B. Aluminum Retainer: Extruded aluminum, alloy 6063-T5 as described in ASTM B221, nominal 0.062" (1.6) thickness.
- C. Closure Caps: Injection molded thermoplastic.

# PART 3 EXECUTION

## 3.01 EXAMINATION

- A. Examine walls for availability of backing to ensure secure attachment of wall protection products.
- B. Verify that HVAC is operating and installation area temperature has been maintained between  $65^{\circ}-75^{\circ}F(18^{\circ}-24^{\circ}C)$  for at least 72 hours prior to installation.
- C. Verify application of wall finishes has been completed in accordance with project finish plan.

#### 3.02 PREPARATION

A. Surface Preparation: Clean substrate to remove dust and debris.

#### 3.03 INSTALLATION

- A. Acclimate materials to building conditions for at least 24 hours prior to installation.
- B. Install wall protection products in accordance with manufacturer's installation instructions.

#### 3.04 PROTECTION

A. Protect installed material from damage by other trades. Use materials that will not mark, stain, or leave residue on the product.