

Suggested Specification
SECTION 10 26 13
Wallguard.com Defender NOW Series PVC Free 2365P

PART 1 GENERAL

1.01 SUMMARY

- A. This section includes the following wall protection system:
 - 1. Corner Guards
- B. Related Sections
 - 1. Section 10 26 16 - Bumper Guards
 - 2. Section 10 26 23 - Protective Wall Covering
 - 3. Section 10 26 33 - Door and Frame Protection
 - 4. Section 09 22 00 - Supports for Plaster and Gypsum Board

1.02 REFERENCES

- A. Abbreviations and Acronyms
 - 1. National Fire Protection Association (NFPA)
 - 2. American Society for Testing and Materials (ASTM)
 - 3. Underwriters Laboratories (UL)
 - 4. American National Standards Institute (ANSI)

1.03 SUBMITTALS

- A. General: Submit the following in accordance with Section 01 33 00 "Submittal Procedures".
- B. Product Data
 - 1. Data sheet illustrating product dimensions, options, and related components.
 - 2. Installation instructions.
- C. Samples for verification of design suitability, color, finish, accessory cap attachment and alignment.
 - 1. 12" (304) Long sample with attached closure cap.
- D. Test reports from a qualified independent laboratory showing results in compliance to requirements indicated

1.04 QUALITY ASSURANCE

- A. Manufacturer to have no less than 5 years experience in the production of wall protection products having successful in-service performance.
- B. Color Control: Provide extruded and molded components that meet visual and colorimetric evaluation of color to a controlled standard.
 - 1. Colorimetric evaluation less than or equal to 1.0 CMC DE (Delta E) when measured under cool white fluorescent lighting.

1.05 DELIVERY, STORAGE, AND HANDLING

- A. Storage: Store wall protection products in original packaging. Protect from weather, extreme temperatures, and moisture.
 - 1. Maintain temperature during storage between 40°- 100°F (4°- 38°C).
 - 2. Store materials flat to prevent twisting or sagging of cartons.
- B. Handling: Take adequate measure to prevent damage to materials. Avoid exposure of plastic products to direct sunlight.

1.06 SITE CONDITIONS

- A. Ambient Conditions: Do not install wall protection products until installation areas are enclosed and weatherproof. HVAC system must be operational and maintaining temperature at 65°-75°F (18°-24°C) for at least 72 hours prior to installation.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Wallguard.com
PO Box 1109
Dover Plains, NY 12522
Tel: 877-943-6826
www.wallguard.com

2.02 DESCRIPTION

- A. Model 2365P, 3" (76) x 3" (76) x 90° Flush mounted corner guard system with a continuous aluminum retainer and 1/4" (6) radius snap-on plastic cover. Outer edges of retainer shall be tapered, ribbed, and perforated for drywall installation. Available with optional 2365P aluminum insert for use with flexible cove base, standard in 4" (102) and 6" (152) length. Select color from manufacturer's standard or custom colors.

2.03 DESIGN AND PERFORMANCE CRITERIA

- A. Flammability Characteristics: Extruded PETG components.
 - 1. Class A Interior wall finish (NFPA 101 Life Safety) when tested in accordance with ASTM E84.
 - a. Flame Spread: 25 or less
 - b. Smoke Developed: 450 or less
- B. Stain Resistance: Extruded PETG components.
 - 1. Material to be tested for stain resistance to various chemical reagents in accordance with ASTM D1308.
- C. Impact Resistance: Extruded PETG components.
 - 1. Unnotched Impact Strength ASTM D4812, 50 ft-lbs/in average, no break.

2.04 MATERIALS

- A. Cover: Extruded PETG, nominal 0.080" (2) thickness, colored throughout.
- B. Aluminum Retainer: Extruded aluminum, alloy 6063-T6 (ASTM B221), nominal 0.070" (1.8) thickness.
- C. Cove Base Insert: Extruded aluminum, alloy 6063-T5 (ASTM B221), nominal 0.062" (1.6) thickness.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Examine walls for availability of backing to ensure secure attachment of wall protection products.
- B. Verify that HVAC is operating and installation area temperature has been maintained between 65°-75°F (18°-24°C) for at least 72 hours prior to installation.

- C. Verify application of wall finishes has been completed in accordance with project finish plan.

3.02 PREPARATION

- A. Surface Preparation: Clean substrate to remove dust and debris.

3.03 INSTALLATION

- A. Acclimate materials to building conditions for at least 24 hours prior to installation.
- B. Install wall protection products in accordance with manufacturer's installation instructions.

3.04 PROTECTION

- A. Protect installed material from damage by other trades. Use materials that will not mark, stain, or leave residue on the product.